

# RCC

## (REGULATORY COMPLIANCE CERTIFICATE)

ISSUED TO

**RIPBOX (PTY) LTD**

IN TERMS OF SANS 10142 CLAUSE 4.

ISSUED BY

**National Regulator for Compulsory Specifications**

*PRODUCT: JUNCTION BOX (RIPBOX) 2010 KBG;*

*Minimum temperature during installation: -5°C ; Protection against ingress of solid objects: IP2X*

*Protection against ingress of water: IPX0*

***Test Laboratory:***

TACS Laboratories (PTY) Ltd.

***In accordance to(Standards):***

SANS 60670-1: 2016

**Test report no:** TJ00246

**RCC No:** 2102009



**Period of Validity**

23/02/2021 to 23/02/2023

*[Signature]*  
**NRCS - Electrotechnical General Manager.**

**DATE**

03 March 2021